



REC 16-158

Knollwood Energy of MA LLC
P.O. Box 30
Chester, New Jersey 07930

January 14, 2016

Debra A. Howland
Executive Director
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

NHPUC 19JAN16PM2:54

Dear Ms Howland,

Enclosed please find applications for 12 systems to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.

Also enclosed are the Simplified Process Interconnection Application and Service Agreement, and the Certificate of Completion.

Electronic versions have been entered into the new online application system under batch number KN16007.

Michael Abbott
Doug Averill
Barrington Rollinsford Mill/Jack Bingham
Timothy Bohlin
Matt Boyer
Alan Brady

Derek Brown
George Chase
John Chirico Jr.
David Ciarla
Bruce Courtney
Shawn Hassell

Please feel free to contact me with any questions or further instructions.
Thank you for your consideration,

Linda Modica
New England REC Operations Manager
Knollwood Energy of MA LLC
973.879.7826
linda@knollwoodenergy.com

NH Public Utilities Commission

REC Aggregator Portal

New Users [CLICK HERE](#) to setup your account for this form. Creating an account enables you to partially complete the form and return later to finish it or to make changes after the form is submitted. Be sure to create your account **BEFORE** entering information into the form, or the information will be lost.

Existing Users [CLICK HERE](#)

Basic Information

Who is submitting this request?

Aggregator

Aggregator Batch Number

KN16007

Aggregator name

Knollwood Energy

Aggregator Email

linda@knollwoodenergy.com

Other Aggregator name

Other aggregator email address

Facility Owner Name

John Chirico Jr.

Facility Owner email

jchiricojr@yahoo.com

Owner Phone

401-301-3241

Facility Address

22 Glasombury Dr.

Facility Town/City

Sandown

Facility State

NH

Facility Zip

03873

Is the facility address the same as the owner's mailing address

- ☒ Yes
☐ No

Mailing Address

Mailing Town/City

Mailing State

Mailing Zip

Primary Contact (who should we call with questions)

Linda Modica

Contact Phone

Other Email Address

Facility Information

Class

II

Utility

Eversource

Other Utility Name

To obtain a GIS ID contact:

James Webb

408 517 2174

jwebb@apx.com

GIS ID (include "NON")

NON60280

Date of Initial Operation

10/22/2015

Facility Operator Name, if applicable

Panel Quantity

45

Panel Make

Other

Panel Model

Other

Panel Rated Output

280

System capacity based on panels

0.1260

Inverter Quantity

45

Inverter Make

Enphase Energy

Inverter Rated Output

250

Add'l Inverter Quantity

NA

Additional Inverter Make

None

Add'l Inverter Model

Rated Output - Primary Inverter

250

Rated Output - Additional Inverter

System capacity based on single inverter make

1.12

System capacity based on two inverter types

System capacity in mW as stated on the interconnection agreement

11.25

Revenue Grade Meter Make

GE

Was this facility installed directly by the customer (no electrician involved)?

- ☐ Yes
☒ No

Electrician Name & Number

Other

Other Electrician Name & Number

Steve Dodd 9613

Installation Company

New Day Energy

Other Installation Company Name

Other Inst. Company Address

Other Inst. Company City

Other Inst. Company State

Other Inst. Company Zip

Independent Monitor Name & Company

Paul Button - Energy Audits Unlimited

Other Monitor Name and Company

Is the installer also the equipment supplier?

- ☒ Yes
☐ No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

https://fs30.formsite.com/jan1947/files/f-5-99-5883416_NgaS1015_N3971_Chirico_Jr_PV_-_Processed_App

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Please attach additional document here


https://fs30.formsite.com/jan1947/files/f-5-168-5883416_iDzF0Dvq_Chirico_COC.pdf

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-173-5883416_wgt7of3M_Chirico_NHOS.pdf

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.



Print Name


Linda Modica

Date Signed

01/14/2016

2 apps = 1 project

EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA
Simplified Process Interconnection Application and Service Agreement



Eversource Application Project ID#: N3971

Contact Information:

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)

Customer or Company Name (print): John Chirico, Jr

Contact Person, if Company: SAUE

Mailing Address: 22 Glastonbury Dr.

City: SANDOWN State: NH Zip Code: 03823-2165

Telephone (Daytime): 601-301-2341 (Evening): SAUE

Facsimile Number: N/A E-Mail Address: John.Chirico@schneider-electric.com

Alternative Contact Information (e.g., System installation contractor or coordinating company, if appropriate):

Name: MARK ROBINSON - NEW DAY ENERGY

Mailing Address: 13 FOSTER LN.

City: KINGSTON State: MA Zip Code: 02364

Telephone (Daytime): 781-679-0715 (Evening): 781-588-4080

Facsimile Number: 781-679-2100 E-Mail Address: MROBINSON@New-Day-Energy.com

Electrical Contractor Contact Information (if appropriate):

Name: STEVE DODD DODD ELECTRIC

Mailing Address: 88 TWIST HILL RD

City: DUNBARTON State: NH Zip Code: 03046

Telephone (Daytime): 603 774 2400 (Evening): 603 765 2711

Facsimile Number: N/A E-Mail Address: DODD6868@GMAIL.COM

Facility Site Information:

Facility (Site) Address: 22 Glastonbury Dr.

City: SANDOWN State: NH Zip Code: 03823-2165

Electric

Service Company: Eversource Account Number: 56998651046 Meter Number: 57111663

Account and Meter Number: Please consult an actual Eversource electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the Eversource Work Request number.

Eversource Work Request # _____

Non-Default Service Customers Only:

Competitive Electric

Energy Supply Company: _____ Account Number: _____

(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)

EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA
Simplified Process Interconnection Application and Service Agreement

Facility Machine Information:

Generator/
Inverter Manufacturer: ENPHASE Model Name & Number: M250 Quantity: 30
Nameplate Rating: 25 (kW) 240 (kVA) 240 (AC Volts) Phase: Single ☒ Three ☐
Nameplate Rating: The AC Nameplate rating of the individual inverter.
System Design Capacity: 725 (kW) 725 (kVA) Battery Backup: Yes ☐ No ☒
System Design Capacity: The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.
Net Metering: If Renewably Fueled, will the account be Net Metered? Yes ☒ No ☐
Prime Mover: Photovoltaic ☒ Reciprocating Engine ☐ Fuel Cell ☐ Turbine ☐ Other ☐
Energy Source: Solar ☒ Wind ☐ Hydro ☐ Diesel ☐ Natural Gas ☐ Fuel Oil ☐ Other ☐

Inverter-based Generating Facilities:

UL 1741 / IEEE 1547.1 Compliant (Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)
Yes ☒ No ☐

The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.

External Manual Disconnect Switch:

An External Manual Disconnect Switch shall be installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'

Yes ☒ No ☐

Location of External Manual Disconnect Switch: above utility meter

Project Estimated Install Date: 9-4-15 Project Estimated In-Service Date: 9-8-15

Interconnecting Customer Signature:

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the **Terms and Conditions for Simplified Process Interconnections** attached hereto:

Customer Signature: [Signature] Title: OWNER Date: 8-30-15

Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the Eversource meter socket. Applications without such a diagram may be returned.

For Eversource Use Only

Approval to Install Facility:

Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.

Are system modifications required? Yes ☐ No ☒ To be Determined ☐

Company Signature: [Signature] Title: Associate Date: 9/4/15
Eng. new

EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA
Simplified Process Interconnection Application and Service Agreement

Facility Machine Information:

Generator/ Inverter Manufacturer: Emphase Model Name & Number: M250 Quantity: 15
Nameplate Rating: 0.25 (kW) 240 (kVA) (AC Volts) Phase: Single ☒ Three ☐
Nameplate Rating: *The AC Nameplate rating of the individual inverter.*
System Design Capacity: 3.75 (kW) (kVA) Battery Backup: Yes ☐ No ☒
System Design Capacity: *The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.*
Net Metering: If Renewably Fueled, will the account be Net Metered? Yes ☒ No ☐
Prime Mover: Photovoltaic ☒ Reciprocating Engine ☐ Fuel Cell ☐ Turbine ☐ Other _____
Energy Source: Solar ☒ Wind ☐ Hydro ☐ Diesel ☐ Natural Gas ☐ Fuel Oil ☐ Other _____

Inverter-based Generating Facilities:

UL 1741 / IEEE 1547.1 Compliant (Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)
Yes ☒ No ☐

The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. *Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.*

External Manual Disconnect Switch:

An External Manual Disconnect Switch shall be installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'

Yes ☒ No ☐

Location of External Manual Disconnect Switch: Directly above Utility Meter

Project Estimated Install Date: 9-18-15 Project Estimated In-Service Date: 9-22-15

Interconnecting Customer Signature:

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the **Terms and Conditions for Simplified Process Interconnections** attached hereto:

Customer Signature: [Signature] Title: OWNER Date: 9-30-15

Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the Eversource meter socket. Applications without such a diagram may be returned.

For Eversource Use Only

Approval to Install Facility:

Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.

Are system modifications required? Yes ☐ No ☒ To be Determined ☐

Company Signature: [Signature] Title: Associate Engineer Date: 9/24/15

Eversource
Interconnection Standards For Inverters Sized Up To 100 kVA
Exhibit B - Certificate of Completion for Simplified Process Interconnections

Installation Information:

☐ Check if owner-installed

Customer or Company Name (print): John Chirico

Contact Person, if Company: SAME

Mailing Address: 24 Glascobury DR

City: SANDOWN State: NH Zip Code: 03873

Telephone (Daytime): 603 361 8341 (Evening): SAME

Facsimile Number: N/A E-Mail Address: JCHIRICOJRE@yahoo.com

Facility Information: →

Eversource Meter # 7111663

Address of Facility (if different from above): Same

City: _____ State: _____ Zip Code: _____

Electrical Contractor Contact Information:

Electrical Contractor's Name (if appropriate): STEVE DODD / DODD ELECTRIC

Mailing Address: 88 TWIST HILL RD

City: DOUBARTON State: NH Zip Code: 03046

Telephone (Daytime): 603 944 2400 (Evening): 603 965 2711

Facsimile Number: N/A E-Mail Address: DODD6565@GMAIL.COM

License number: 9613

Date of approval to install Facility granted by the Company: _____

Eversource Application ID number: #N 3121

Inspection:

The system has been installed and inspected in compliance with the local Building/Electrical Code of:

City: SANDOWN, NH County: Rockingham

Signed (Local Electrical Wiring Inspector or an authorized signed electrical inspection):

Signature: Thomas Tamburello Electrical Inspector

Name (printed): Thomas Tamburello Date: 10/22/2015

Customer Certification:

I hereby certify that, to the best of my knowledge, all information contained in this Exhibit B – Certification of Completion is true and correct. This system has been installed and shall be operated in compliance with applicable standards. Also, the initial start-up test required by Puc. 905.04 has been successfully completed.

Please remember to provide digital photos of the installation, including the AC disconnect switch (if required), the existing Eversource meter, the inverters, and the point of electrical interconnection.

Customer Signature: [Signature]

As a condition of interconnection you are required to send fax a copy of this form to:

Eversource
Distributed Generation
780 North Commercial Street
P. O. Box 330, Manchester, NH 03105-0330
Fax No.: (603) 634-2924

New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

John N Chiric Jr

Printed Name of signature owner

John N. Chirico Jr
John N Chirico Jr (Dec 8, 2015)

Signature of system owner